

**Village District of Edelweiss**  
**Water Committee Meeting – 10-14-2022**  
**Water System Facilities Tour – Beginning at the Office Parking Lot**  
**Minutes**

Call to Order at 8:00am by LL

Attendees:

In-person: Larry Leonard, Larry Sodano, Doug Prescott, Wooda McNiven  
Ian Hayes & Ryan – from Simply Water

Purpose of this meeting is to tour pump house facilities for Committee training and for collecting information on possible projects & system needs.

Chemical Room – DPW Garage:

- Add Ph probes for monitoring
- New Eye-Wash Sink – has been approved & is pending installation

DPW Well:

- Note that neither the DPW Lot entrance nor the road over to the well from the Lot are secured.  
Currently access to the primary well is wide open.

Jungfrau Pump Station:

- No comments

Reinach Tank:

- Need to add inflow meter
- Need to add check valve
- Need to redo the outflow to the Reinach Pressure Zone to move it from the inflow pipe to the outflow pipe
- Need to locate the CSVs outside the building
- Need to obtain As-Built Documentation

Muddy Beach Pump House:

- Floor needs a vapor barrier & concrete slab
- Need to cut back brush around the House
- Need to clear soil away from the bottom of the exterior walls – this is rotting the siding

Oak Pump Station:

- Need to add air-release valves – the trapped air is burning out the pump motors  
(“Ball valve bleeder?”)

Chocorua Pump Station:

- No comments

Summit Station:

- Need to spray foam the walls & ceiling:
  - Thermal issue (heating)
  - Critters have easy access now
- One tank is old and is currently off-line
- Need to add transducers in the tanks to monitor levels – there is an existing plan to add these???
- Need to add inflow & outflow meters

All Stations:

- Add generator?
  - Is there an Emergency Management Grant available??
- Site Work:
  - There are trees growing on top of buried tanks
  - There are tree branches touching power lines to the stations
  - There is brush & dirt up against the outside walls
  
- Add more isolation valves throughout the District
- Add more blowoffs
- Add flow arrows on pipes (like at Summit Station)
- Add valve tags to connect each to documentation

Motion to adjourn at 11:00am by DP, 2<sup>nd</sup> by WM Approved 4-0

Respectfully submitted,  
Douglas T. Prescott