

2024 Consumer Confidence Report (2023 data)

Village District of Eidelweiss

PWS ID#1461010

Introduction

Like any responsible public water system, our mission is to deliver the best quality drinking water and reliable service at an appropriate cost. Aging infrastructure presents challenges to drinking water safety, and continuous improvement is needed to maintain the quality of life we desire for today and for the future.

In 2023 the VDOE dealt with a number of natural disasters from flash floods that washed out water mains, to extreme blizzards that discontinued power for days. With the increased frequency of these issues, the board is working with different parties exploring options to better protect our assets and try to maintain continuous water flow. We have also been dealing with a uranium overage from the Muddy Beach well site. We are again exploring different options and costs for these wells to best address this issue. The Muddy Beach wells have always shown some signs of uranium. Muddy Beach crossed over the Maximum Contaminate Level (MCL) in the early part of 2023, but the MCL numbers steadily dropped and leveled out at their previous norms. As of the end of the 2023 year the Running Annual Average (RAA) for uranium was at 30.5 with an MCL of 30 putting us 1.66% over the limit. This issue is from natural changes to the groundwater and not due to a treatment failure, as we do not currently have any equipment designed, or required for uranium removal. In April of 2024 the Muddy Beach well site again crossed over the MCL. The VDOE notified all the users and is conducting quarterly testing, as required by NHDES. Moving forward the board will continue to look for opportunities in grant funding to help initiate projects and offset what is becoming an ever-increasing cost to supply water. These investments along with on-going operation and maintenance costs are supported by water user fees. When considering the high value we place on water, it is truly a bargain to have water service that pro-

TECTS public health and provides us with the high-quality of life we enjoy.

What is a Consumer Confidence Report?

The Consumer Confidence Report (CCR) details the quality of your drinking water, where it comes from, and where you can get more information. This annual report documents all detected primary and secondary drinking water parameters and compares them to their respective standards known as Maximum Contaminant Levels (MCLs).

NOW IT COMES WITH A
LIST OF INGREDIENTS.



The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-

products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The US Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

What is the source of my drinking water?

Our water comes from 2 Bedrock wells located at 134 Eidelweiss Drive, commonly referred to as Muddy Beach well field, and one Gravel packed well located at 1680 Conway Road, commonly referred to as the DPW well. The water is treated to raise pH with Sodium Hydroxide, commonly referred to as Caustic Soda.

Why are contaminants in my water? Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Do I need to take special precautions? Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Source Water Assessment Summary

DES prepared drinking water source assessment reports for all public water systems between 2000 and 2003 in an effort to assess the vulnerability of each of the state's public water supply sources. Included in the report is a map of each source water protection area, a list of potential and known contamination sources, and a summary of available protection options. [The results of the assessment, prepared on 8/31/2000](#) is noted below:

Muddy Beach Bedrock Well (BRW-007) received 1 high susceptibility rating, 0 medium susceptibility ratings, and 11 low susceptibility ratings. Muddy Beach Bedrock Well (BRW-008) received 1 high susceptibility rating, 0 medium susceptibility ratings, and 11 low susceptibility ratings. DPW Gravel Packed Well (GPW-010) received 2 high susceptibility ratings, 3 medium susceptibility ratings, and 7 low susceptibility ratings.

Note: This information is over 20 years old and includes information that was current at the time the report was completed. Therefore, some of the ratings might be different if updated to reflect current information. At the present time, DES has no plans to update this data.

The complete Assessment Report is available for review at VDOE's office. For more information, call the office at 603-367-9022, or visit the DES Drinking Water Source Assessment website at <http://des.nh.gov/organization/divisions/water/dwgb/dwspp/dwsap.htm>.

How can I get involved?

The best way to get involved is to attend VDOE's Commissioner's meetings, which are posted on the VDOE website and bulletin boards. If there are specific issues you wish to be considered at the meeting, please call ahead to be placed on the agenda. The VDOE phone number is 603-367-9022.

For more information about your drinking water, please call the VDOE office at 603-367-9022, or the primary operator, Simply Water at 603-730-5297. Although we do not have specific dates for public participation events or meetings, feel free to contact us with any questions you may have.

Violations and Other information:

No violations.

Definitions

Ambient Groundwater Quality Standard or AGQS: The maximum concentration levels for contaminants in groundwater that are established under RSA 485-C, the Groundwater Protection Act.

Action Level or AL: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Abbreviations

BDL: Below Detection Limit

mg/L: milligrams per Liter

NA: Not Applicable

ND: Not Detectable at testing limits

NTU: Nephelometric Turbidity Unit

pCi/L: picoCurie per Liter

ppb: parts per billion

ppm: parts per million

RAA: Running Annual Average

TTHM: Total Trihalomethanes

UCMR: Unregulated Contaminant Monitoring Rule

ug/L: micrograms per Liter

The following applies if these contaminants are present – see table for detected levels.

Drinking Water Contaminants:

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water system is responsible for high quality drinking water but cannot control the variety of materials used in your plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water from your tap for at least 30 seconds before using water for drinking or cooking. Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://water.epa.gov/drink/info/lead/index.cfm>

System Name: Village District of Eidelweiss PWS ID: 1461010
2024 Report (2023 Data)

VIOLATIONS

VIOLATIONS	Date of violation	Explain violation	Length of violation	Action taken to resolve	Health Effects (Env-Dw 804-810)
MCL / SAMPLE AVERAGE VIOLATION	4/1/2023	URANIUM / (MASS units in ug/L)	327 Days	CONTINUED MONITORING	SEE BELOW
MCL / SAMPLE AVERAGE VIOLATION	1/1/2023	URANIUM / (MASS units in ug/L)	417 Days	CONTINUED MONITORING	SEE BELOW

LEAD AND COPPER

Contaminant (Units)	Action Level (AL)	90th percentile sample value *	Date	# of sites above AL	Violation Yes/No	Likely Source of Contamination	Health Effects of Contaminant
Copper (ppm)	1.3	0.532	10/5/2023	10	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
Lead (ppb)	15	0.003	10/5/2023	10	NO	Corrosion of household plumbing systems, erosion of natural deposits	(15 ppb in more than 5%) Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791). (Above 15 ppb) Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

DETECTED WATER QUALITY RESULTS

Microbiological Contaminants

Contaminant (Units)	Level Detected*	Date	MCL	MCLG	Violation YES/NO	Likely Source of Contamination	Health Effects of Contaminant
Barium (ppm)	0.0107	1/20/2021	2	2	NO	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.
Fluoride (ppm)	1.17 MG/L	1/202/2021	4.0	4.0	NO	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.
Nitrate (as Nitrogen) (ppm)	0.49 MG/L	1/9/2023	10	10	NO	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	(5 ppm through 10ppm) Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider. (Above 10 ppm) Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

SECONDARY CONTAMINANTS

Secondary MCLs (SMCL)	Level Detected	Date	Treatment technique (if any)	SMCL	50 % AGQS (Ambient groundwater quality standard)	AGQS (Ambient groundwater quality standard)	Specific contaminant criteria and reason for monitoring
Chloride (ppm)	80 MG/L	1/20/2021	N/A	250	N/A	N/A	Wastewater, road salt, water softeners, corrosion
Iron (ppm)	0.012 MG/L	1/22/2021	N/A	0.3	N/A	N/A	Geological
Manganese (ppm)	0.0106 MG/L	1/20/2021	N/A	0.05	0.15	0.3	Geological
PH (ppm)	6.99 SU	1/20/2021	N/A	6.5-8.5	N/A	N/A	Precipitation and geology
Sodium (ppm)	6.6 MG/L	1/20/2021	N/A	100-250	N/A	N/A	We are required to regularly sample for sodium
Sulfate (ppm)	4 MG/L	1/20/2021	N/A	250	250	500	Naturally occurring
Zinc (ppm)	0.0170	1/26/2021	N/A	5	N/A	N/A	Galvanized pipes
PH (ppm)	6.99	1/19/2021	N/A	6.5-8.5	N/A	N/A	Precipitation and geology

Radioactive Contaminants

Contaminant (Units)	Level Detected*	Date	MCL	MCLG	Violation YES/NO	Likely Source of Contamination	Health Effects of Contaminant
Compliance Gross Alpha (pCi/L)	6.9	3/18/2020	15	0	NO	Erosion of natural deposits	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
Uranium (ug/L)	Running Annual AVG: 30.5 Range: 20.3-42.1	1/4/23-11/28/23	30	0	NO	Erosion of natural deposits	Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity.

PER- AND POLYFLUOROALKYL SUBSTANCES (PFAS) CONTAMINANTS

Contaminant (Units)	Level Detected*	Date	MCL	MCLG	Violation YES/NO	Likely Source of Contamination	Health Effects of Contaminant
Perfluorooctanoic acid (PFOA) (ppt)	1.78N/GL	12/25/2023	12	0	NO	Discharge from industrial processes, wastewater treatment, residuals from firefighting foam, runoff/leachate from landfills and septic systems	Some people who drink water containing perfluorooctanoic acid (PFOA) in excess of the MCL over many years could experience problems with their liver, endocrine system, or immune system, may experience increased cholesterol levels, and may have an increased risk of getting certain types of cancer. It may also lower a woman's chance of getting pregnant.

ADDITIONAL TESTING

Additional Tests	Description of data requested	Date	Treatment technique (if any)	Results (with units)	Specific contaminant criteria and reason for monitoring
UCMR detects	Lithium	3/15/2023	N/A	13.9 ug/L	Our system is participating in EPA's Unregulated Contaminant Monitoring Rule (UCMR) program to increase understanding of these unregulated contaminants and their distribution in drinking water throughout the United States
UCMR detects	Lithium	8/22/2023	N/A	12.8 ug/L	Our system is participating in EPA's Unregulated Contaminant Monitoring Rule (UCMR) program to increase understanding of these unregulated contaminants and their distribution in drinking water throughout the United States